



TO: All Plan Holders

RE: **ALLEGANY HIGH SCHOOL REPLACEMENT**  
Allegany County Public Schools

Please find the enclosed Addendum No. 2, dated February 12, 2016. Addendum No. 2 consists of the following:

Cover sheet –	1 page
Addendum No. 2, dated 02/12/16	4 pages
Standard Form of Proposal (00 41 13)	7 pages
List Of Drawings (00 82 00)	10 pages
Sketch, Architectural	1 page
30x42 drawing sheet, Plumbing	1 drawing sheet
Planholders list (current as of this writing)	2 pages



February 12, 2016

**ALLEGANY HIGH SCHOOL REPLACEMENT  
ADDENDUM NO. 2  
21306.00/060**

TO THE CONTRACT DRAWINGS AND SPECIFICATIONS FOR THE REFERENCED PROJECT, DATED JANUARY 26, 2016, AS PREPARED BY GRIMM & PARKER ARCHITECTS, 11720 BELTSVILLE DRIVE, SUITE 600, CALVERTON, MARYLAND 20705.

This Addendum includes changes and clarifications to the Contract Documents. The information includes the following:

**GENERAL ITEMS:**

ITEM NO. 2.1

The following items are a few topics discussed during the original bid phase last July. The posting of them in this addenda is to provide a courtesy reminder.

Prevailing Wage

- A. The work is to be performed based on prevailing wage rates. All policies, procedures, and filings must be made in accordance with the requirement of the Contract Documents and the State of Maryland.
- B. Per State requirements, all wage rate forms will be required to be electronically submitted on a weekly basis.

Minority Business Enterprise

- A. Project requirements for minority participation in this project are defined in the project Specifications.
- B. Bids received without the required MBE forms indicated shall be deemed non-responsive.
- C. The typical State MBE goal is 28%. This project has a MBE participation goal of 10%. Because of this lower percentage number, it is unlikely that any waivers will be entertained.
- D. There are no MBE sub-goals for this project.

Bonding & Licensing

Bonding and licensing must be by companies authorized to perform said business within the State of Maryland.

Lion's Center

- A. Uninterrupted access to Lion's Center for staff, visitors, and emergency vehicles must be maintained at all times. Project sequencing indicates access requirements when work occurs on facility access drive.
- B. Coordinate and schedule utility disruptions to not place undue burden on Lion's Center facility.
- C. Communicate, through Owner, in a timely manner all work which may have an impact on the daily operations of the Lion's Center.
- D. The primary means of construction access to the site should be via Seton Ave. Bishop Walsh access should be minimized and use should be coordinated with the Lion's Center.

- E. It should be understood by bidders that through the previous demolition phase, the Lion's Center has been a very cooperative and understanding neighbor.

Dust Control

Contractor will be required to be in strict control of dust from migrating off-site to adjacent neighbors. Residents of Lion's Center with respiratory issues make this a critical issue that we want to be mindful of through the construction process.

**SPECIFICATION ITEMS:**

ITEM NO. 2.2	<u>SECTION 00 41 13 – STANDARD FORM OF PROPOSAL</u>
<b>SUBSTITUTE</b>	Section in its entirety with attached new Standard Form of Proposal. This new proposal revises some incorrect language that was contained in Bid Alternate No. 14A.
ITEM NO. 2.3	<u>SECTION 00 82 00 – LIST OF DRAWINGS</u>
<b>SUBSTITUTE</b>	Section in its entirety with attached new Section.
ITEM NO. 2.4	<u>SECTION 08 43 13 – ALUMINUM FRAMED ENTRANCES AND STOREFRONT</u>
Para 2.2.A.1	STOREFRONT
<b>REVISE</b>	Glazing Position to be " <b>Front</b> ".
Para 2.3D	Sunshades
<b>DELETE</b>	Paragraph in its entirety.
ITEM NO. 2.5	<u>SECTION 12 61 00 – FIXED AUDIENCE SEATING</u>
<b>DELETE</b>	The project specifications contain two sections of 12 61 00. The first section also includes "BID ALTERNATE 14" in the section title. <b>This section remains.</b> Delete the second occurrence of the section that does not contain the above in the section title.
ITEM NO. 2.6	<u>SECTION 28 31 11 – FIRE ALARM SYSTEMS (ADDRESSABLE TYPE)</u>
<b>REVISE</b>	Subparagraph 2.3.A shall be revised to read: " <b><i>The catalog numbers used are those of Edwards and constitute the type and quality of equipment to be furnished. Provide Edwards System only. No substitutions shall be accepted.</i></b> "

**DRAWING ITEMS:**

**TITLE SHEETS**

ITEM NO. TS2.1	<u>SHEETS TS-1.2 &amp; TS02.2 – LIST OF DRAWINGS – VOL 1 &amp; VOL 2</u>
<b>DELETE</b>	C3.1a PROPOSED SITE GRADING PLAN – ADD ALTERNATE from the list of drawings.
<b>REVISE</b>	C7.3 PROPOSED UTILITY PROFILES to be numbered Sheet <b>C7.3.1</b> .
<b>ADD</b>	<b>C7.6 PROPOSED UTILITY PROFILES</b> to the list of drawings.
<b>DELETE</b>	E-6.4 ELECTRICAL DETAILS from the list of drawings.
<b>DELETE</b>	E-6.5 ELECTRICAL DETAILS from the list of drawings.

**CIVIL**

ITEM NO. C2.1	<u>SHEET C6.1 – PROPOSED WALL INDEX</u>
<b>REVISE</b>	Sheet number to be <b>C6.0</b> to match list of drawings on sheets TS1.2 and TS2.2.

**ARCHITECTURAL**

ITEM NO. A2.1	<u>SHEET A-3.1 – DOOR SCHEDULE</u>
<b>REVISE</b>	Aluminum storefront door thickness, per project Specifications, shall be 2”.
ITEM NO. A2.2	<u>SHEET A-4.2 – BUILDING SECTIONS</u>
<b>ADD</b>	Dimensions <b>3'-4"</b> and <b>2'-8"</b> to the Box Office ticket windows (dimension is to bottom of sill).
ITEM NO. A2.3	<u>SHEET A-9.0 0 EQUIPMENT AND FURNISHING SCHEDULES</u>
<b>ADD</b>	Remark <b>1</b> to Music Casework items M1 thru M11.
<b>ADD</b>	Remark <b>2</b> to Music Casework item M12.
<b>ADD</b>	The following Remark descriptions to the Music Casework Schedule: <b>1. PROVIDE WITH MANUFACTURER'S METAL GRILLE DOORS</b> <b>2. PROVIDE WITH MANUFACTURER'S WOOD DOORS</b>
ITEM NO. A2.4	<u>SHEET A-9.1A – ENTRY LEVEL FURNITURE PLAN – PARTIAL AREA A</u>
<b>ADD</b>	Detail reference <b>K11/A-9.3</b> to countertops in Dressing Rooms A143 and A145

*ALLEGANY HIGH SCHOOL REPLACEMENT  
ADDENDUM NO. 2*

- ITEM NO. A2.5                    SHEET A-9.2A – UPPER LEVEL FURNITURE PLAN – PARTIAL AREA A
- ADD**                                Detail reference **G11/A-9.3** to the curved countertop in Control Booth A202 (countertop is 24” deep)
- 
- ITEM NO. A2.6                    SHEET A-9.3 – MILLWORK DETAILS
- ADD**                                Detail K11 (Dressing Room Counter Dtl.) – see attached sketch A2.1. Mount countertop at 3’0” AFF.
- PLUMBING**
- ITEM NO. P2.1                    SHEET P-6.3 DOMESTIC WATER RISER DIAGRAMS
- SUBSTITUTE**                    Drawing P6.3 that was included in Bid Set 2 suffered a printer error and was incomplete. The resubmission of this sheet displays the full domestic water riser. – See attached replacement sheet P-6.3.
- ELECTRICAL**
- ITEM NO. E2.1                    SHEET E-0.2, LIGHTING FIXTURE SCHEDULE
- ADD**                                Definition for Fixture Type H2 as follows:  
“Description: 4' LINEAR WALL MOUNTED LIGHT, WITH 20-GAUGE COLD ROLLED STEEL FIXTURE CHANNEL AND EXTRUDED ALUMINUM FRONT HOUSING; AND ACRYLIC .125" SHIELDING. Manufacturer: HE WILLIAMS, PARAMOUNT IN. or METALUX, Catalog Number: WMA-4-232-A-EB2-UNV, Volts: 277, Input Watts: 56,        Lamp: (2) F32T8 4100K, 3100 LUMENS PHILIPS F32T8/ADV841/ALTO,        Mounting: Wall 14’0” Above Finished Floor”
- 
- ITEM NO. E2.2                    SHEET E-0.5, SITE PLAN - ELECTRICAL
- DELETE**                            Delete second sheet labelled E-0.5 in the Bid Set. (First sheet indicates fixtures properly located and complete circuit connection.)
- 
- ITEM NO. E2.3                    SHEET E-2.0C, LOWER FLOOR PLAN – LIGHTING
- REVISE**                            Exterior fixtures indicated outside 2D Studio/Computer Graphics C034 labelled “AU” and outside Kiln/Ceramic Storage C037 labelled “AJ” to “AG.”
- 
- ITEM NO. E2.4                    SHEET E-2.1A, ENTRY FLOOR PLAN – PARTIAL AREA A - LIGHTING
- CLARIFY**                            Three exterior fixtures outside Vestibule A10 with Drawing Note 8 reference shall be type “AJD.”
- 
- ITEM NO. E2.5                    SHEET E-2.2A, UPPER FLOOR PLAN – PARTIAL AREA A - LIGHTING
- CLARIFY**                            Exterior fixture outside Vestibule B21 with Drawing Note 4 reference shall be type “AJD.”

\*\*\*\*\*

**SECTION 00 41 13**

**STANDARD FORM OF PROPOSAL**

**Allegany High School Replacement**

**Bid Documents Dated:** \_\_\_\_\_

**Owner**

Board of Education of  
Allegany County, Maryland  
108 Washington Street  
Cumberland, Maryland 21502

**Contractor:** \_\_\_\_\_

**Architect**

Grimm + Parker Architects  
11720 Beltsville Drive  
Suite 600  
Calverton, MD 20705  
Phone: 301-595-1000  
Email: [Seschbach@gparch.com](mailto:Seschbach@gparch.com)

**Phone:** \_\_\_\_\_

**Email:** \_\_\_\_\_

The undersigned, having visited and carefully examined the site and carefully examined the Bid Announcements and all Bid Documents do hereby submit our proposal to the Board of Education of Allegany County for the award of Contract for the project Allegany High School Replacement. This proposes to furnish all labor, specified materials and specified equipment necessary to properly complete all of the work required in strict accordance with the aforesaid documents using only the specified manufacturer's materials for the Lump Sum as follows:

A. BASE BID

**Lump Sum Bid:** \_\_\_\_\_ **Dollar**

(\$ \_\_\_\_\_)

B. ALLOWANCES

The above stated Lump Sum Bid shall include the following listed allowances. Any allowance balance unused at the end of construction shall be remanded back to the Owner.

- 1. Electrical Technology Equipment Allowance \$400,000.00
- 2. Tubular skylight dimming systems to include all required wiring, Conduit, boxes, and switching to be located in Rm. C104. \$8,000.00

C. ALTERNATE BIDS

*Special Instructions:* Submit a bid on each of the alternates as identified in the bid documents and listed below. Do not enter “No Bid”. If the alternate does not affect your price, enter \$0.00 (zero dollars). **Indicate whether the price quoted is an add or a deduct.** If no indication is made, the quote will be considered an add.

**Bid Alternate No. 1:** NOT USED

**Bid Alternate No. 2A:** NOT USED

**Bid Alternate No. 2B:** NOT USED

**Bid Alternate No. 2C:** NOT USED

**Bid Alternate No. 2D:** Provide and install all Football/Soccer field turf upgrades and all other items indicated in the Contract referring to Bid Alternate 2D.

Base Bid: Provide and install Football/Soccer field not indicated in the Contract Documents as elements of Bid Alternate 2D.

**Bid Alternate No. 2D:** \_\_\_\_\_ (\$ \_\_\_\_\_)  
(Words) (Figures)

**Bid Alternate No. 2E:** Provide and install all Running Track surface upgrades and all other items indicated in the Contract referring to Bid Alternate 2E.

Base Bid: Provide and install Running Track surfaces not indicated in the Contract Documents as elements of Bid Alternate 2E.

**Bid Alternate No. 2E:** \_\_\_\_\_ (\$ \_\_\_\_\_)  
(Words) (Figures)

**Bid Alternate No. 2F:** NOT USED

**Bid Alternate No. 2G:** NOT USED

**Bid Alternate No. 2H:** NOT USED

**Bid Alternate No. 3:** Provide fully welded joints for ALL heating and chilled water piping 2-1/2” and larger located within Boiler Room B207 and Chiller Room B208.

Base Bid: Provide Victaulic zero flex rigid couplings (Sole Source) and piping with roll grooved joints for heating and chilled water piping 2-1/2” and larger located within Boiler Room B207 and Chiller Room B208.

**Bid Alternate No. 3:** \_\_\_\_\_ (\$ \_\_\_\_\_ )  
(Words) (Figures)

**Bid Alternate No. 4A:** NOT USED

**Bid Alternate No. 4B:** NOT USED

**Bid Alternate No. 5:** Provide geothermal VRF heat pump condensing units, geothermal bore field and all associated equipment and piping to serve the VRF system for the Administration, Guidance, and Health suites, as indicated on the Contract Documents.

Base Bid: Provide air source VRF heat pump condensing units and all associated equipment and piping to serve the VRF system for the Administration, Guidance, and Health suites, as indicated on the Contract Documents.

**Bid Alternate No. 5:** \_\_\_\_\_ (\$ \_\_\_\_\_ )  
(Words) (Figures)

**Bid Alternate No. 6:** NOT USED

**Bid Alternate No. 7A:** Provide and install epoxy terrazzo flooring (TRZ) at Vestibule A10 (around perimeter of walk-off mat) and Student Commons A13 to extent indicated in the Contract Documents.

Base Bid: Provide and install finishes indicated in Finish Schedule on Drawing Sheet A-3.2.

**Bid Alternate No. 7A:** \_\_\_\_\_ (\$ \_\_\_\_\_ )  
(Words) (Figures)



**Bid Alternate No. 7B:** NOT USED

**Bid Alternate No. 7C:** NOT USED

**Bid Alternate No. 7D:** NOT USED

**Bid Alternate No. 8:** At all railings in Student Commons B24, B25, and Stair ST3, provide and install Decorative Metal Railing System with perforated in-fill panels, as specified in Specification Section 05 73 00.

Base Bid: Provide painted steel picket-type guard rail as indicated in the Drawings.

**Bid Alternate No. 8:** \_\_\_\_\_ (\$ \_\_\_\_\_ )  
(Words) (Figures)

**Bid Alternate No. 9:** NOT USED

**Bid Alternate No. 10:** Provide and install pipe grid system TV Studio room C107 as indicated in the Documents

Base Bid: Provide only indicated electrical rough-in for future performance lighting and equipment related to Bid Alternate 10.

**Bid Alternate No. 10:** \_\_\_\_\_ (\$ \_\_\_\_\_ )  
(Words) (Figures)

**Bid Alternate No. 11:** Provide fully hard-wired data connections at computer labs C007, C012, C014, and C101 to include all wiring conduit, boxes and terminations as indicated in the documents as related to Bid Alternate 11.

Base Bid: Provide wireless data connections as indicated in the documents.

**Bid Alternate No. 11:** \_\_\_\_\_ (\$ \_\_\_\_\_ )  
(Words) (Figures)

**Bid Alternate No. 12:** NOT USED

**Bid Alternate No. 13:** NOT USED

**Bid Alternate No. 14A:** Provide and install all auditorium seating specified in Section 12 61 00 – FIXED AUDIENCE SEATING and as shown in the Drawings.

Base Bid: Construct auditorium without fixed audience seating.

**Bid Alternate No. 14A:** \_\_\_\_\_ (\$ \_\_\_\_\_ )  
(Words) (Figures)

**Bid Alternate No. 14B:** Provide and install curved acoustic cloud system, ceiling type APC6 with all required mounting sub-framing, support systems, and appurtenances.

Base Bid: Construct auditorium without curved acoustic clouds, ceiling type APC6 .

**Bid Alternate No. 14B:** \_\_\_\_\_ (\$ \_\_\_\_\_ )  
(Words) (Figures)

**Bid Alternate No. 15:** Contractor shall provide and grade all topsoil required and as indicated in the Documents.

Base Bid: Owner will furnish all topsoil required and will stockpile on-site. Contractor will supply necessary soil amendments to comply with the requirements of the Documents.

**Bid Alternate No. 15:** \_\_\_\_\_ (\$ \_\_\_\_\_ )  
(Words) (Figures)

D. ADDENDA

Receipt of the following Addenda is acknowledged:

Addenda No. _____	Dated _____	Addenda No. _____	Dated _____
Addenda No. _____	Dated _____	Addenda No. _____	Dated _____
Addenda No. _____	Dated _____	Addenda No. _____	Dated _____

E. PROPOSED SUBSTITUTION

Indicate proposed substitutions below and attached copies of “Substitution Request Form” referenced in Section 01 60 00A.

<u>Proposed Substitution</u>	<u>Price Change</u>
_____	\$ _____
_____	\$ _____
_____	\$ _____
_____	\$ _____
_____	\$ _____
_____	\$ _____

F. WARRANTY TO THE LUMP SUM

The undersigned affirms that the Base Bid stated above represents the entire cost of the Project in accordance with the Bid Documents and that no claim shall be made on account of any increase in wage scales, materials prices, taxes, insurance, cost indexes, or any other rate affecting the construction industry and/or this project.

If the undersigned receives written notice of the acceptance of this proposal, at his/her designated address within sixty (60) days after the bid opening (or later if the bid has not been withdrawn), the undersigned agrees to execute and deliver a contract and bonds in accordance with the bid as accepted, within seven (7) days after receiving notice, or forfeit the amount of the bid bond.

**Affidavit:**

\_\_\_\_\_, being first duly sworn deposes and says that he/she is an officer in the building construction organization known as \_\_\_\_\_, and the party making a certain proposal or bid date \_\_\_\_\_, 2015 to the Board of Education of Allegany County, Maryland. And that this Bid is genuine and not collusive or sham; that said bidder has not colluded, conspired, connived or agreed, directly or indirectly, with any bidder or person to put in a sham bid or to refrain from bidding, and has not in any manner, directly or indirectly, sought by agreement or collusion, or communication or conference, with any person to fix the bid prices of the affidavit or any other bidder, or to fix any overhead, profit or cost element of said bid price, or that of any bidder, or to secure any advantage against the Board of Education of Allegany County or any other person interested in the proposed contract; and that all statements in said proposal or bid are true.

Signature of:

X \_\_\_\_\_

Bidder if the bidder is an individual

\_\_\_\_\_  
Name and Title (printed)

Registered Maryland Contractor No. \_\_\_\_\_

**OR**

X \_\_\_\_\_

Partner if the bidder is a partnership

\_\_\_\_\_  
Name and Title (printed)

Registered Maryland Contractor No. \_\_\_\_\_

**OR**

X \_\_\_\_\_

Officer if the bidder is a corporation

\_\_\_\_\_  
Name and Title (printed)

Registered Maryland Contractor No. \_\_\_\_\_

**ALL**

Subscribed and sworn before me this \_\_\_\_\_ day of \_\_\_\_\_, 2015.

X \_\_\_\_\_

Notary Public

My Commission expires: \_\_\_\_\_

**NOTE:** The following items shall be completed and submitted as attachments to the Bid:

1. Section 00 43 13 Bid Bond
2. Section 00 45 13 Affidavit of Qualification to bid, to include AIA Document A305
3. Section 00 43 63 AIA Form A305 – Contractor’s Qualification Statement
4. Section 00 62 39 Minority Business Enterprise Utilization Affidavit and the MBE Participation Schedule.

**LIST OF DRAWINGS**VOLUME 1

TS-1.1 TITLE SHEET - VOL 1  
TS-1.2 LIST OF DRAWINGS - VOL 1

CIVIL

C0.0 TITLE SHEET  
C0.1 LIST OF SYMBOLS AND ABBREVIATIONS  
C0.2 STANDARD SITE DETAILS  
C0.3 STANDARD SITE DETAILS  
C0.4 STANDARD SITE DETAILS  
C0.5 STANDARD SITE DETAILS  
C0.6 STANDARD SITE DETAILS  
C0.7 STANDARD SITE DETAILS  
C0.8 STANDARD SITE DETAILS  
C0.9 MANHOLE INLET SCHEDULES  
C1.0 EXISTING OVERALL SITE AND DEMO PLAN  
C2.0 PROPOSED OVERALL SITE PLAN - BASE BID  
C2.1 PROPOSED SITE PLAN - BASE BID  
C2.2 PROPOSED SITE PLAN - BASE BID  
C2.3 PROPOSED SITE PLAN - BASE BID  
C2.4 PROPOSED SITE PLAN - BASE BID  
C2.5 PROPOSED SITE PLAN - BASE BID  
C2.6 PROPOSED SITE PLAN - BASE BID  
C2.7 PROPOSED PAVING AND SIGNAGE PLAN  
C3.0 PROPOSED SITE GRADING PLAN - BASE BID  
C3.1 PROPOSED SITE GRADING PLAN - BASE BID  
C3.2 PROPOSED SITE GRADING PLAN - BASE BID  
C3.3 PROPOSED SITE GRADING PLAN - BASE BID  
C3.4 PROPOSED SITE GRADING PLAN - BASE BID  
C3.5 PROPOSED SITE GRADING PLAN - BASE BID  
C3.6 PROPOSED SITE GRADING PLAN - BASE BID  
C4.0 EROSION AND SEDIMENT CONTROL PLAN PHASE 1  
C4.1 EROSION AND SEDIMENT CONTROL PLAN PHASE 1  
C4.2 EROSION AND SEDIMENT CONTROL PLAN PHASE 2  
C4.3 EROSION AND SEDIMENT CONTROL PLAN PHASE 2  
C4.4 EROSION AND SEDIMENT CONTROL DETAILS  
C4.5 EROSION AND SEDIMENT CONTROL DETAILS  
C4.6 EROSION AND SEDIMENT CONTROL DETAILS  
C5.0 PROPOSED MICRO-BIORETENTION MB#1  
C5.1 PROPOSED MICRO-BIORETENTION MB#2  
C5.2 PROPOSED MICRO-BIORETENTION MB#3  
C6.0 PROPOSED WALL INDEX

C6.1	PROPOSED WALL PROFILES
C6.2	PROPOSED WALL PROFILES
C6.3	PROPOSED WALL DETAILS
C6.4	PROPOSED WALL DETAILS
C7.0	PROPOSED UTILITY PROFILES
C7.1	PROPOSED UTILITY PROFILES
C7.2	PROPOSED UTILITY PROFILES
C7.3	PROPOSED UTILITY PROFILES
C7.3.1	PROPOSED UTILITY PROFILES
C7.4	PROPOSED UTILITY PROFILES
C7.5	PROPOSED UTILITY PROFILES
C7.6	PROPOSED UTILITY PROFILES
C8.0	REMOVAL OF OVERBURDEN SITEPLAN
L1.0	LANDSCAPE PLAN
L2.0	LANDSCAPE PLAN - DETAILS
L3.0	LANDSCAPE PLAN - DETAILS

### ARCHITECTURAL

A-0.1	PRELIMINARY CODE STUDY - LOWER FLOOR PLAN
A-0.2	PRELIMINARY CODE STUDY - ENTRY FLOOR PLAN
A-0.3	PRELIMINARY CODE STUDY - UPPER FLOOR PLAN
A-0.4	LOWER FLOOR PLAN - OVERALL
A-0.5	ENTRY FLOOR PLAN - OVERALL
A-0.6	UPPER FLOOR PLAN - OVERALL
A-0.8	OUTDOOR STORAGE BLDG PLANS, ELEVATIONS, SECTIONS AND DETAILS
A-1.0C	LOWER LEVEL FLOOR PLAN - PARTIAL AREA C
A-1.1A	ENTRY LEVEL FLOOR PLAN - PARTIAL AREA A
A-1.1B	ENTRY LEVEL FLOOR PLAN - PARTIAL AREA B
A-1.1C	ENTRY LEVEL FLOOR PLAN - PARTIAL AREA C
A-1.2A	UPPER LEVEL FLOOR PLAN - PARTIAL AREA A
A-1.2B	UPPER LEVEL FLOOR PLAN - PARTIAL AREA B
A-1.2C	UPPER LEVEL FLOOR PLAN - PARTIAL AREA C
A-1.3	MECHANICAL PENTHOUSE PLANS
A-1.4	ROOF PLAN
A-1.5	ROOF DETAILS
A-1.6	ROOF DETAILS
A-1.7	ROOF DETAILS
A-2.1	BUILDING ELEVATIONS
A-2.2	BUILDING ELEVATIONS
A-2.3	BUILDING ELEVATIONS
A-2.4	BUILDING ELEVATIONS
A-2.5	BUILDING AXONS
A-3.1	DOOR SCHEDULE
A-3.2	FINISH SCHEDULE

---

A-3.3	HEAD, SILL, AND JAMB DETAILS
A-3.4	WALL TYPES AND WALL TERMINATION DETAILS
A-3.5	FRAME ELEVATIONS - HOLLOW METAL AND CURTAIN WALL
A-3.6	FRAME ELEVATIONS - STOREFRONT
A-3.7	FRAME ELEVATIONS - STOREFRONT
A-3.8	STOREFRONT DETAILS
A-3.9	STOREFRONT DETAILS
A-3.10	CURTAINWALL DETAILS
A-3.11	WALL SECTION DETAILS
A-4.0	BUILDING SECTIONS
A-4.1	BUILDING SECTIONS
A-4.2	BUILDING SECTIONS
A-4.3	BUILDING SECTIONS
A-4.4	BUILDING SECTIONS
A-4.5	WALL SECTIONS @ MUSIC AREA
A-4.6	WALL SECTIONS @ ADMIN. / GREENHOUSE
A-4.7	WALL SECTIONS @ CLASSROOM WING
A-4.8	WALL SECTIONS @ CLASSROOM WING P.H.
A-4.9	WALL SECTIONS @ DINING & KITCHEN
A-4.10	WALL SECTIONS @ WEST ENTRANCE
A-4.11	WALL SECTIONS @ GYM
A-4.12	WALL SECTIONS @ GYM
A-4.13	WALL SECTIONS @ MECH. & CLASSROOM
A-4.14	WALL SECTIONS @ KITCHEN & MECH.
A-4.15	WALL SECTIONS @ SOUTH ENTRANCE
A-4.16	WALL SECTIONS
A-4.17	WALL SECTIONS @ THEATRE
A-4.18	WALL SECTIONS @ THEATRE
A-4.19	WALL SECTIONS @ THEATRE
A-5.1	ENLARGED STAIR PLANS AND SECTIONS
A-5.2	ENLARGED STAIR PLANS AND SECTIONS
A-5.3	ENLARGED STAIR PLANS AND SECTIONS
A-5.4	ENLARGED STAIR PLANS AND SECTIONS
A-5.5	ENLARGED STAIR PLANS AND SECTIONS
A-5.6	STAIR & RAILING DETAILS
A-5.8	ENLARGED TOILET PLANS
A-5.9	TYPICAL DETAILS
A-5.10	PLAN DETAILS
A-5.11	PLAN DETAILS
A-5.12	PLAN DETAILS
A-6.1	INTERIOR ELEVATIONS
A-6.2	INTERIOR ELEVATIONS
A-6.3	INTERIOR ELEVATIONS
A-6.4	INTERIOR ELEVATIONS
A-6.5	INTERIOR ELEVATIONS
A-6.6	INTERIOR ELEVATIONS

A-6.7	INTERIOR ELEVATIONS
A-6.8	INTERIOR ELEVATIONS
A-6.9	INTERIOR ELEVATIONS
A-6.10	INTERIOR ELEVATIONS
A-6.11	INTERIOR ELEVATIONS
A-7.0C	LOWER LEVEL RCP - PARTIAL AREA C
A-7.1A	ENTRY LEVEL RCP - PARTIAL AREA A
A-7.1B	ENTRY LEVEL RCP - PARTIAL AREA B
A-7.1C	ENTRY LEVEL RCP - PARTIAL AREA C
A-7.2A	UPPER LEVEL RCP - PARTIAL AREA A
A-7.2B	UPPER LEVEL RCP - PARTIAL AREA B
A-7.2C	UPPER LEVEL RCP - PARTIAL AREA C
A-7.3	CEILING DETAILS
A-9.0	EQUIPMENT AND FURNISHING SCHEDULES
A-9.0C	LOWER LEVEL FURNITURE PLAN - PARTIAL AREA C
A-9.1A	ENTRY LEVEL FURNITURE PLAN - PARTIAL AREA A
A-9.1B	ENTRY LEVEL FURNITURE PLAN - PARTIAL AREA B
A-9.1C	ENTRY LEVEL FURNITURE PLAN - PARTIAL AREA C
A-9.2A	UPPER LEVEL FURNITURE PLAN - PARTIAL AREA A
A-9.2B	UPPER LEVEL FURNITURE PLAN - PARTIAL AREA B
A-9.2C	UPPER LEVEL FURNITURE PLAN - PARTIAL AREA C
A-9.3	MILLWORK DETAILS
A-9.4	MILLWORK DETAILS
A-9.5	AUDITORIUM DETAILS
A-9.6	AUDITORIUM DETAILS

### KITCHEN

K101	KITCHEN EQUIPMENT PLAN
K102	BUILDING CONDITIONS & VENTILATION PLAN
K103	PLUMBING ROUGH-IN PLAN
K104	ELECTRICAL ROUGH-IN PLAN
K502	UTILITY RACEWAY DETAILS
K503	VENTILATOR DETAILS
K504	VENTILATOR WIRING DIAGRAM

### STRUCTURAL

S-0.0	GENERAL NOTES
S-0.1	INSPECTION TABLES
S-0.2	SCHEDULES
S-1.0C	LOWER LEVEL FOUNDATION AND SLAB ON GRADE - AREA C
S-1.1A	ENTRY LEVEL FOUNDATION AND SLAB ON GRADE PLAN - AREA A
S-1.1B	ENTRY LEVEL FOUNDATION AND SLAB ON GRADE PLAN - AREA B
S-1.1C	ENTRY LEVEL FLOOR FRAMING PLAN - AREA C
S-1.2A	UPPER LEVEL FLOOR AND LOW ROOF FRAMING PLAN - AREA A



S-1.2B	UPPER LEVEL FLOOR AND LOW ROOF FRAMING PLAN - AREA B
S-1.2C	UPPER LEVEL FLOOR AND LOW ROOF FRAMING PLAN - AREA C
S-1.3A	MECHANICAL PENTHOUSE FLOOR AND ROOF FRAMING PLAN - AREA A
S-1.3B	MECHANICAL PENTHOUSE FLOOR AND ROOF FRAMING PLAN - AREA B
S-1.3C	MECHANICAL PENTHOUSE FLOOR AND ROOF FRAMING PLAN - AREA C
S-1.4A	HIGH ROOF FRAMING PLAN - AREA A
S-1.4B	HIGH ROOF FRAMING PLAN - AREA B
S-1.4C	HIGH ROOF FRAMING PLAN - AREA C
S-1.5	PARTIAL PLANS - AREA C - ALTERNATE NO.1
S-2.1	BRACE FRAME ELEVATIONS
S-2.2	COLUMN, BASE PLATE, PIER, AND FOOTING SCHEDULE- AREA A
S-2.3	COLUMN, BASE PLATE, PIER, AND FOOTING SCHEDULE- AREA A
S-2.4	COLUMN, BASE PLATE, PIER, AND FOOTING SCHEDULE- AREA B
S-2.5	COLUMN, BASE PLATE, PIER, AND FOOTING SCHEDULE- AREA C
S-2.6	COLUMN, BASE PLATE, PIER, AND FOOTING SCHEDULE – AREA C
S-3.1	TYPICAL DETAILS
S-3.2	TYPICAL DETAILS
S-3.3	TYPICAL DETAILS
S-3.4	TYPICAL DETAILS
S-4.1	SECTIONS
S-4.2	SECTIONS
S-4.3	SECTIONS
S-5.1	SECTIONS
S-5.2	SECTIONS
S-5.3	SECTIONS
S-5.4	SECTIONS
S-5.5	SECTIONS
S-5.6	SECTIONS
S-5.7	SECTIONS
S-5.8	SECTIONS
S-5.9	SECTIONS
S-5.10	SECTIONS

VOLUME 2

TS-2.1	TITLE SHEET - VOL 2
TS-2.2	LIST OF DRAWINGS - VOL 2

MECHANICAL

MPS-1.1	MECHANICAL & PLUMBING SITE PLAN
MP-2.1	OUTDOOR STORAGE BUILDING FLOOR PLANS

---

M-0.1	MECHANICAL GENERAL NOTES & LEGEND
M-2.0C	LOWER FLOOR PLAN - PARTIAL AREA C
M-2.1A	ENTRY FLOOR PLAN - PARTIAL AREA A
M-2.1B	ENTRY FLOOR PLAN - PARTIAL AREA B
M-2.1C	ENTRY FLOOR PLAN - PARTIAL AREA C
M-2.2A	UPPER FLOOR PLAN - PARTIAL AREA A
M-2.2B	UPPER FLOOR PLAN - PARTIAL AREA B
M-2.2C	UPPER FLOOR PLAN - PARTIAL AREA C
M-2.3	ROOF PLAN
M-3.1	BOILER/CHILLER ROOM & PENTHOUSE #1 LOWER LEVEL PART PLAN - AREA B
M-3.2	BOILER/CHILLER ROOM & PENTHOUSE #1 UPPER LEVEL PART PLAN - AREA B
M-3.3	MECHANICAL PENTHOUSE #2 LOWER LEVEL PART PLAN - AREA A
M-3.4	MECHANICAL PENTHOUSE #2 UPPER LEVEL PART PLAN - AREA A
M-4.3	MECHANICAL PENTHOUSE #3 - AREA A
M-3.6	MECHANICAL PENTHOUSE #4 LOWER LEVEL PART PLAN - AREA C
M-3.7	MECHANICAL PENTHOUSE #4 UPPER LEVEL PART PLAN - AREA C
M-5.1	MECHANICAL SECTIONS
M-5.2	MECHANICAL SECTIONS
M-5.3	MECHANICAL SECTIONS
M-5.4	MECHANICAL SECTIONS
M-7.1	CENTRAL COOLING PLANT PIPING DETAILS
M-7.2	CENTRAL HEATING PLANT, CONDENSER WATER AND HYDRONIC PIPING DETAILS
M-7.3	HYDRONIC PIPING DETAILS
M-7.4	EQUIPMENT DETAILS
M-7.5	AIR DISTRIBUTION SYSTEM DETAILS
M-7.6	INDUSTRIAL DUCT AND MISCELLANEOUS DETAILS
M-7.7	ROOF CURB, SUPPORT, AND FUEL OIL SYSTEM DETAILS
M-7.8	GEOHERMAL AND VRF SYSTEM DETAILS
M-7.9	AIR HANDLING UNIT DETAILS
M-7.10	AIR HANDLING UNIT DETAILS
M-8.1	CENTRAL COOLING PLANT CONTROL DIAGRAM
M-8.2	CENTRAL HEATING PLANT CONTROL DIAGRAM
M-8.3	DEDICATED OUTDOOR AIR SYSTEM CONTROL DIAGRAM
M-8.4	VAV AIR HANDLING UNIT CONTROL DIAGRAM
M-8.5	VAV AIR HANDLING UNIT W/ HEAT RECOVERY CONTROL DIAGRAM
M-8.6	TYPICAL GYMNASIUM, AUX GYM, AND AUDITORIUM AIR HANDLING UNIT CONTROL DIAGRAM
M-8.7	TYPICAL 100% O/A HEAT RECOVERY AIR HANDLING UNIT CONTROL DIAGRAM
M-8.8	DINING/KITCHEN AIR HANDLING UNIT CONTROL DIAGRAM
M-8.9	MAIN LOBBY AIR HANDLING UNIT CONTROL DIAGRAM
M-8.10	VRV, VAV, AND KITCHEN HOOD SYSTEMS CONTROL DIAGRAMS
M-8.11	MISCELLANEOUS MECHANICAL CONTROL DIAGRAMS

M-8.12	LOWER FLOOR PLAN - AUTOMATIC TEMPERATURE CONTROLS
M-8.13	ENTRY FLOOR PLAN - AUTOMATIC TEMPERATURE CONTROLS
M-8.14	UPPER FLOOR PLAN - AUTOMATIC TEMPERATURE CONTROLS
M-9.1	AIR HANDLING UNIT & EQUIPMENT SCHEDULES
M-9.2	TERMINAL CONTROL UNIT & EQUIPMENT SCHEDULES
M-9.3	MECHANICAL SCHEDULES
M-9.4	MECHANICAL EQUIPMENT NOTES & SCHEDULES

## PLUMBING

P-0.1	PLUMBING EQUIPMENT, SCHEDULES, & LEGEND
P-2.00A	FOUNDATION PLAN - PARTIAL AREA A
P-2.00B	FOUNDATION PLAN - PARTIAL AREA B
P-2.00C	FOUNDATION PLAN - PARTIAL AREA C
P-2.0C	LOWER FLOOR PLAN - PARTIAL AREA C
P-2.1A	ENTRY FLOOR PLAN - PARTIAL AREA A
P-2.1B	ENTRY FLOOR PLAN - PARTIAL AREA B
P-2.1C	ENTRY FLOOR PLAN - PARTIAL AREA C
P-2.2A	UPPER FLOOR PLAN - PARTIAL AREA A
P-2.2B	UPPER FLOOR PLAN - PARTIAL AREA B
P-2.2C	UPPER FLOOR PLAN - PARTIAL AREA C
P-2.3	ROOF PLAN
P-3.1	MECHANICAL PENTHOUSE #2, #3 & #4
P-6.1	SANITARY/VENT RISER DIAGRAMS
P-6.2	SANITARY/VENT RISER DIAGRAMS
P-6.3	DOMESTIC WATER RISER DIAGRAMS
P-6.4	DOMESTIC WATER AND NATURAL GAS RISER DIAGRAMS
P-6.5	SANITARY AND NATURAL GAS RISER DIAGRAMS
P-7.1	PIPING DETAILS
P-7.2	EQUIPMENT DETAILS
P-7.3	EQUIPMENT DETAILS

## FIRE PROTECTION

FP-2.1	LOWER FLOOR PLAN - SPRINKLER ZONES
FP-2.2	ENTRY FLOOR PLAN - SPRINKLER ZONES
FP-2.3	UPPER FLOOR PLAN - SPRINKLER ZONES
FP-2.4	PENTHOUSE FLOOR PLAN - SPRINKLER ZONES
FP-7.1	FIRE PROTECTION DETAILS

## ELECTRICAL

E-0.1	ELECTRICAL LEGEND, CONVENTIONS & ABBREVIATIONS
E-0.2	LIGHTING FIXTURE SCHEDULE
E-0.3	LIGHTING FIXTURE SCHEDULE
E-0.4	SITE PLAN – ELECTRICAL

E-0.5	SITE PLAN - ELECTRICAL
E-1.0C	LOWER FLOOR PLAN - PARTIAL AREA C - POWER
E-1.1A	ENTRY FLOOR PLAN - PARTIAL AREA A - POWER
E-1.1B	ENTRY FLOOR PLAN - PARTIAL AREA B - POWER
E-1.1C	ENTRY FLOOR PLAN - PARTIAL AREA C - POWER
E-1.2A	UPPER FLOOR PLAN - PARTIAL AREA A - POWER
E-1.2B	UPPER FLOOR PLAN - PARTIAL AREA B - POWER
E-1.2C	UPPER FLOOR PLAN - PARTIAL AREA C - POWER
E-1.3	ROOF PLAN - ELECTRICAL
E-2.0C	LOWER FLOOR PLAN - LIGHTING
E-2.1A	ENTRY FLOOR PLAN - PARTIAL AREA A - LIGHTING
E-2.1B	ENTRY FLOOR PLAN - PARTIAL AREA B - LIGHTING
E-2.1C	ENTRY FLOOR PLAN - PARTIAL AREA C - LIGHTING
E-2.2A	UPPER FLOOR PLAN - PARTIAL AREA A - LIGHTING
E-2.2B	UPPER FLOOR PLAN - PARTIAL AREA B - LIGHTING
E-2.2C	UPPER FLOOR PLAN - PARTIAL AREA C - LIGHTING
E-2.3	PENTHOUSE NO. 2 AND NO. 4 PART PLANS - LIGHTING
E-3.0C	LOWER FLOOR PLAN - FIRE ALARM
E-3.1A	ENTRY FLOOR PLAN - PARTIAL AREA A - FIRE ALARM
E-3.1B	ENTRY FLOOR PLAN - PARTIAL AREA B - FIRE ALARM
E-3.1C	ENTRY FLOOR PLAN - PARTIAL AREA C - FIRE ALARM
E-3.2A	UPPER FLOOR PLAN - PARTIAL AREA A - FIRE ALARM
E-3.2B	UPPER FLOOR PLAN - PARTIAL AREA B - FIRE ALARM
E-3.2C	UPPER FLOOR PLAN - PARTIAL AREA C - FIRE ALARM
E-3.3	PENTHOUSE NO. 2 AND NO. 4 PART PLANS - FIRE ALARM
E-4.1	MECHANICAL ROOMS, PENTHOUSE
E-4.2	MECHANICAL PENTHOUSES #2 & #3
E-4.3	MECHANICAL PENTHOUSE #4
E-4.4	PART PLAN - KITCHEN - ELECTRICAL
E-4.5	ELEVATOR AND AUDITORIUM PART PLANS
E-4.6	CATWALK PLANS
E-4.7	FIELD HOUSE PLANS
E-5.1	SCHEMATIC POWER RISER DIAGRAM
E-5.2	FIRE ALARM RISER DIAGRAM
E-6.1	ELECTRICAL DETAILS
E-6.2	ELECTRICAL DETAILS
E-6.3	ELECTRICAL DETAILS
E-7.1	PANELBOARD SCHEDULES
E-7.2	PANELBOARD SCHEDULES
E-7.3	PANELBOARD SCHEDULES
E-7.4	PANELBOARD SCHEDULES
E-7.5	PANELBOARD SCHEDULES
E-7.6	PANELBOARD SCHEDULES
E-7.7	PANELBOARD SCHEDULES
E-7.8	SOLAR PHOTOVOLTAIC INFORMATION
E-7.9	MECHANICAL CONNECTION SCHEDULES

---

**E-7.10 MECHANICAL CONNECTION SCHEDULES****TELECOMMUNICATION**

T-0.1	SITE PLAN - TELECOM
TE-0.1	LEGEND, ABBR., & GENERAL NOTES
TE-1.3A	MECHANICAL PENTHOUSES - TELECOM
TE-1.3C	MECHANICAL PENTHOUSES - TELECOM
TE-1.0C	LOWER FLOOR PLAN - TELECOM
TE-1.1A	ENTRY FLOOR PLAN - PARTIAL AREA A - TELECOM
TE-1.1B	ENTRY FLOOR PLAN - PARTIAL AREA B - TELECOM
TE-1.1C	ENTRY FLOOR PLAN - PARTIAL AREA C - TELECOM
TE-1.2A	UPPER FLOOR PLAN - PARTIAL AREA A - TELECOM
TE-1.2B	UPPER FLOOR PLAN - PARTIAL AREA B - TELECOM
TE-1.2C	UPPER FLOOR PLAN - PARTIAL AREA C - TELECOM
TE-1.3A	MECHANICAL PENTHOUSES - TELECOM
TE-1.3C	MECHANICAL PENTHOUSES - TELECOM
TE-1.4	FLOOR PLANS - CLASSROOM ALT - TELECOM
TE-3.0	TELECOM RISER DIAGRAM
TE-4.0	TECHNOLOGY DETAILS
TE-4.1	TECHNOLOGY DETAILS
TE-4.2	TECHNOLOGY DETAILS

**SECURITY**

T-0.2	SITE PLAN - SECURITY
TE-2.0A	FLOOR PLANS - CLASSROOM ALT - SECURITY
TE-2.0C	LOWER FLOOR PLAN - SECURITY
TE-2.1A	ENTRY FLOOR PLAN - PARTIAL AREA A - SECURITY
TE-2.1B	ENTRY FLOOR PLAN - PARTIAL AREA B - SECURITY
TE-2.1C	ENTRY FLOOR PLAN - PARTIAL AREA C - SECURITY
TE-2.2A	UPPER FLOOR PLAN - PARTIAL AREA A - SECURITY
TE-2.2B	UPPER FLOOR PLAN - PARTIAL AREA B - SECURITY
TE-2.2C	UPPER FLOOR PLAN - PARTIAL AREA C - SECURITY
TE-4.3	SECURITY DETAILS
TE-4.4	SECURITY DETAILS

**THEATER**

T-1.1A	ENTRY FLOOR PLAN - PARTIAL AREA A - THEATER
T-1.2A	UPPER FLOOR PLAN - PARTIAL AREA A - THEATER
T-2.2A	UPPER CEILING PLAN - PARTIAL AREA A - THEATER
T-2.3A	MECHANICAL PENTHOUSES - THEATER
T-3.1	THEATER LIGHTING AND RIGGING DETAILS
T-3.2	DIMMING SYSTEM RISER DIAGRAM

T-3.3	STAGE LIGHTING AND CONTROL DETAILS
T-3.4	STAGE LIGHTING DETAILS
T-3.5	DIMMING SYSTEM RACK SCHEDULE
T-3.6	THEATER LIGHTING AND SOUND SYSTEM DETAILS
T-3.7	TV STUDIO PART PLAN - THEATER

GRIMM + PARKER ARCHITECTS

Calverton, MD  
301-595-1000 (P)

JOB ALLEGANY H.S. REPLACEMENT

SHEET NO. \_\_\_\_\_ OF \_\_\_\_\_

CALCULATED BY \_\_\_\_\_ DATE \_\_\_\_\_

CHECKED BY \_\_\_\_\_ DATE 2.10.16

SCALE 1/2" = 1'-0"

DRAWING A-2.1

WALL MIRROR - SEE  
PLAN FOR SIZE

3/4" PLAN SHELF w/  
3/4" PLAN VERT SUPPORTS  
@ 3'-0" O.C. MAX - ALIGN  
w/ COUNTER TOP BRACKETS

1/4" P. LAM COUNTER-TOP

P. LAM BACKSPASH

PRE-MANUFACTURED  
COUNTER BRACKET  
@ 3'-0" O.C. MAX -  
SEE SPEC.


2" GRONNET @  
3'-0" O.C. MAX -  
CENTER ON SHELF  
VERTICAL SUPPORTS

SCHEDULED BASE


DRESSING ROOM COUNTER DTL.

1/2" = 1'-0"

K11



**DOMESTIC WATER FLOW DIAGRAM - AREA B**  
SCALE: NOT TO SCALE



**DOMESTIC WATER RISER DIAGRAMS**  
SCALE: NOT TO SCALE

STATE OF MARYLAND  
PROFESSIONAL ENGINEER

Professional Certification: I hereby certify that these documents were prepared or approved by me, and that I am a duly licensed professional engineer under the laws of the State of Maryland. License No.: 38222 Expiration Date: 01/05/2016

**Gipe Associates Inc.**  
Consulting Engineers  
849 Farmington Ave. Suite 102, Baltimore, MD 21286  
Tel: 410-522-6688  
Fax: 410-522-6689  
www.gipe.com

**GP #21306**

THIS DRAWING AND THE DESIGN AND CONSTRUCTION THEREOF ARE THE PROPERTY OF GIPE ASSOCIATES, INC. AND SHALL NOT BE ALIENED OR REUSED IN WHOLE OR IN PART WITHOUT THE EXPRESS WRITTEN PERMISSION OF GIPE ASSOCIATES, INC. Copyright © 2015

11720 Beltsville Drive  
Suite 600  
Calverton, MD 20705  
Tel: 301.995.1000  
www.grimmandparker.com

**GRIMM AND PARKER**

**DOMESTIC WATER RISER DIAGRAMS**

**ALLEGHANY HIGH SCHOOL**  
CUMBERLAND, MD

DATE	DESCRIPTION

**P-6.3**  
01/26/2016  
BID SET 2



**Allegany High School Replacement – Phase II  
Bidder’s List - Construction – Rebid**

<b>Business Name/Address</b>	<b>Contact Person</b>	<b>Phone</b>	<b>E Mail Address</b>	<b>Check #</b>
R.H. Lapp & Sons, Inc. 880 Kelly Road Cumberland, MD 21502	George Lapp	301-724-6650	<a href="mailto:glapp@rhlapp.com">glapp@rhlapp.com</a>	Pick up
Mascaro Construction Company, L.P. 1720 Metropolitan Street Pittsburgh, PA 15233	Kathy Agostino	412-321-4901	<a href="mailto:buildings@mascaroconstruction.com">buildings@mascaroconstruction.com</a>	FedEx
Walter N. Yoder & Sons, Inc P.O. Box 1337 16200 McMullen Highway, SW Cumberland, MD 21501-1337	Linda Burgess	301-729-0610	<a href="mailto:lburgess@wnyoder.com">lburgess@wnyoder.com</a>	Pick up
Manheim Corporation 2025 Greentree Road Pittsburg, PA 15220	Bryan Scott	412-306-0534	<a href="mailto:bscott@manheimcorp.com">bscott@manheimcorp.com</a>	Pick Up
Dustin Construction 2510 Urbana Pike, Suite 201 Ijamsville, MD 21754	Daniel Heftner	301-810-4320	<a href="mailto:jpickett@dustinconstruction.com">jpickett@dustinconstruction.com</a>	UPS
Leonard S. Fiore, Inc. 5506 Sixth Avenue – Rear Altoona, PA 16602	Angel M. Farabaugh	814-946-3686	<a href="mailto:afarabaugh@lsfiore.com">afarabaugh@lsfiore.com</a> <a href="http://www.lsfiore.com">www.lsfiore.com</a>	UPS
Envirotrols Group, Inc. P.O. Box 467 Delmar, DE 19940	Jeff Vernon	302-846-9103	<a href="mailto:jeffv@telcoenvirotrols.com">jeffv@telcoenvirotrols.com</a>	UPS
P.J. Dick Incorporated P.O. Box 6774 Pittsburgh, PA 15212	Doug Brown	412-807-2000	<a href="mailto:doug.brown@pjdick.com">doug.brown@pjdick.com</a>	Pick up
Hite Associates, Inc. P.O. Box 1273 Cumberland, MD 21502	Randy Rice	301-729-8900	<a href="mailto:rrice@thebeltgroup.com">rrice@thebeltgroup.com</a>	Pick up
Braddock Construction, LLC 16214 National Highway, SW Frostburg, MD 21532	Dave Walker Dave Weimer	301-689-5979	<a href="mailto:davewalker@braddockconstructionllc.com">davewalker@braddockconstructionllc.com</a>	Pick up
Somers Steel P.O. Box 98 Boswell, PA 15531	Jim Cuningham Larry Myers	301-722-3980	<a href="mailto:lwm@lceci.com">lwm@lceci.com</a>	Pick up
S & S Electric, Inc. 2252 Frankfort Hwy Ridgeley, WV 26753	Sean Strietbeck	304-738-9406	<a href="mailto:sselectric.sean@atlanticbb.net">sselectric.sean@atlanticbb.net</a>	Pick up
HD Supply P.O. Box 764 Martinsburg, WV 25402	Mike Leadman Mark Sterling	304-263-6986 304-263-6986	<a href="mailto:michael.leadman@hdsupply.com">michael.leadman@hdsupply.com</a> <a href="mailto:mark.sterling@hdsupply.com">mark.sterling@hdsupply.com</a>	Pick up

Excavating Associates, Inc. P.O. Box 434 Ellerslie, MD 21529-0434	Larry Weigle	301-777-0444	<a href="mailto:lweigle@excavatingassociates.com">lweigle@excavatingassociates.com</a>	
Pittsburgh Builders Exchange 1813 N. Franklin Street Pittsburgh, PA 15223	Jen Carter	717-307-9999	<a href="mailto:jen@pbe.org">jen@pbe.org</a> <a href="mailto:pbxproduction@pbe.org">pbxproduction@pbe.org</a>	UPS
Dodge Data & Analytics 3315 Central Avenue Hot Springs, AR 71913	Suzanne Kennison	860-474-5387	<a href="mailto:Suzanne.Kennison@construction.com">Suzanne.Kennison@construction.com</a>	FedEx
Allegany Aggregates Inc. 21235 National Pike Flintstone, MD 21530	Dave Bennett	301-777-1777	<a href="mailto:concroxdave@hereintown.net">concroxdave@hereintown.net</a>	Pick up
Chaney Construction Management, LLC Town Center Building 115 Baltimore Street, Suite 300 Cumberland, MD 21502	Steve Chaney	301-876-1472 301-777-1335	<a href="mailto:chaney808@yahoo.com">chaney808@yahoo.com</a>	