

AMENDMENT OF SOLICITATION OF CONTRACT		1. CONTRACT ID CODE	NO. OF PAGES 2
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 3	3. EFFECTIVE DATE 02/17/14	4. REQ/PURCHASE REQ. NO.	5. PROJECT NO. (if applicable) LEW13-17
6. ISSUED BY:  ATK Tactical Systems Company LLC Allegany Ballistics Laboratory Rocket Center, WV 26726		7. ADMINISTERED BY (if other than item 6)  ATK Tactical Systems Company LLC Allegany Ballistics Laboratory Rocket Center, WV	
8. NAME AND ADDRESS OF CONTRACTOR (NO., STREET, COUNTY, STATE AND ZIP CODE)		9A. AMENDMENT OF SOLICITATION NO. LEW13-17	
		9B. DATED (SEE ITEM 11) 01/23/14	
		10A. MODIFICATION OF CONTRACT/ORDER NO.	
		10B. DATED (SEE ITEM 13)	

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is Not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning  1  copy of the amendment; (b) **By acknowledging receipt of this amendment on each copy of the offer submitted; FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.** If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

**12. ACCOUNTING AND APPROPRIATION DATA (if required)**

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

A. This change order is issued pursuant to: (specify authority) The changes set forth in Item 14 are made in the Contract Order No. in Item 10A

B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation date, etc.) set forth in Item 14, pursuant to the authority of FAR 43.103(b).

C. This supplemental agreement is entered into pursuant to authority of:

D. Other (specify type of modification and authority)

**E. IMPORTANT:** Contractor is not required to sign this document and return to the issuing office. (Reference box 11 above)

**14. DESCRIPTION OF AMENDMENT/MODIFICATION**

See Attachment A

Except as provided herein, all terms and conditions of the document referenced in Item 9A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (type or print)  Lisa Wildman, Contracting Officer
15B. CONTRACTOR/OFFEROR  (Signature of person authorized to sign)      Date Signed	16B. SIGNATURE  <i>Lisa Wildman</i> 02/17/14  (Signature of Contracting Officer)      Date Signed

**Attachment A**  
**AMENDMENT NO. 3 Dated 02/17/14**  
**Steam Plant Water Facility**  
**Bid Package LEW13-17**

This amendment is issued to incorporate the information listed below into this Solicitation. Please be sure to acknowledge receipt of Amendment 1, 2, and 3 on your Solicitation, Offer, and Award form when submitting your bid.

1. It shall be the responsibility of the contractor to perform exploratory excavations for all utilities that are indicated on the project drawings and to repair said utilities if they are damaged.
2. All utility relocations not indicated on project drawings are not the responsibility of the contractor.
3. It is anticipated that adequate backfill material will be generated by site construction activities. If project site backfill is not available, suitable backfill material shall be provided by ATK.
4. Delete requirement for concrete cradles for Specification 02200 Section 3.07 item F
5. Regarding Specification 02200 Section 3.08 Item A.2: Contractor will be reimbursed based on time and material if soft or unsuitable material is encountered and additional over excavation is required. All additional work shall be authorized by ATK before proceeding.
6. The current Erosion and Sediment Control Plan have been approved by WVCA and their requirements are included in these plans.
7. All water retaining structures shall contain a waterstop. A concrete key shall be installed so that they do not interfere with wall reinforcing per Building 863 Drawing S-11.
8. Threaded rebar couplings may be used in the construction joints and wall corner as an alternative. Contractor shall submit cut sheets to ATK for prior approval before construction.
9. Modify Specification 03100 Section 3.03 Item A to indicate that all concrete forms may be re-used.
10. Information regarding the thickness of the roof, wall and liner panels can be located in Specification 13122 Section 2.01 Items E, F and G.
11. Delete reference to Building 863 Drawing E-4A as referenced on Building 863 Drawing E-3. Drawing E-4A does not exist.
12. Additional clarification regarding item #1 of Addendum #2 regarding the requirement of fire-proofing for the Chemical Room (Room #3) only is as follows: The 1 inch rigid polystyrene insulation shall be located on top of each purlin only. The remainder of the underside of the metal roof shall be fire-proofed.
13. Amendment 2, Item 12 is hereby retracted. Precast concrete is still an option for the sedimentation/flocculation basin.