

ADDENDUM No. 1

BERKELEY COUNTY PUBLIC SERVICE WATER DISTRICT

**POTOMAC RIVER WATER TREATMENT FACILITY
CIP CHEMICAL FEED UPGRADE**

- **CONTRACT No. 4: GENERAL - MECHANICAL AND ELECTRICAL WORK**

BERKELEY COUNTY, WV

OCTOBER 17, 2017

PREPARED BY:

**GWIN, DOBSON & FOREMAN, INC.
CONSULTING ENGINEERS
ALTOONA, PA 16602
(814) 943-5214**

FOR:

**BERKELEY COUNTY PUBLIC SERVICE
WATER DISTRICT
251 CAPERTON BOULEVARD
MARTINSBURG, WV 25403**

PLEASE ACKNOWLEDGE RECEIPT OF ADDENDUM NO. 1 BELOW AND RETURN TO GD&F VIA FAX (814) 943-8494 OR E-MAIL AKORDISH@GDFENGINEERS.COM.

THE BIDDER MUST ALSO RECORD AND ACKNOWLEDGE RECEIPT OF ALL ADDENDA (INCLUDING THE NUMBERS AND DATES) ON THE BID FORM.

NAME	TITLE	DATE
-------------	--------------	-------------

FIRM

ADDENDUM NO. 1

- A.** Bidders are instructed to record and acknowledge receipt of this Addendum No. 1 in the appropriate section of the respective bid forms, Section 00300: BID FORM CONTRACT NO. 4: GENERAL-MECHANICAL AND ELECTRICAL WORK. Failure to do so may subject the Bidder to disqualification.
- B. SCOPE**
1. This Addendum No. 1 shall be part of the Contract Documents and consist of pages ADD1-1 to ADD1-2.
 2. The following revisions, interpretations, and/or supplementations pertaining to the Contract Documents for the Project are addressed by Addendum No. 1.
- C. SPECIFICATIONS**
1. Section 00100: INVITATION FOR BIDS
 - a. Revise the first sentence of the first paragraph on Page 00100-1 to read the following:

"Sealed bids will be received by the Berkeley County Public Service Water District for the Potomac River Water Treatment Facility CIP Chemical Feed Upgrade until 5:00 PM, prevailing time, on November 13, 2017 at the Berkeley..."
 2. Section 00500: AGREEMENT BETWEEN OWNER AND CONTRACTOR FOR CONSTRUCTION CONTRACT (STIPULATED PRICE)
 - a. Under Article 4.02, change substantially completed within 90 days to 120 days. Change ready for final payment within 100 days to 130 days.
 2. Section 16111: CONDUIT
 - a. Revise Part 3.02, D. to the following:

"Use schedule 40 PVC conduit for all exposed interior and exterior work."
- D. DRAWINGS**
1. SHEET NO. D-1: C.I.P. SYSTEM DEMOLITION FLOOR PLAN
 - a. Demolition Note Clarification: The Owner will be responsible for disposing of existing chemicals once they are placed into existing day tanks by Contractor.

2. SHEET NO. E-2: LIQUID CHEMICAL FEED STATIONS MODIFICATION POWER AND DEMOLITION PLANS

- a. Programming Clarification: The Contractor will not be responsible for any programming required within the SCADA system. The Contractor will be responsible for properly labeling or re-labeling all wires at the Remote I/O Rack so that the Membrane System Manufacturer can make the necessary programming changes. The Owner will hire the Membrane System Manufacturer under separate contract to perform the necessary programming changes. Coordination between the Contractor and Membrane System Manufacturer may be required to complete the programming modifications.

GWIN, DOBSON & FOREMAN, INC.



(Seal)

Christopher M. Eckenrode
Christopher M. Eckenrode, P.E.
Senior Project Engineer

Date: October 17, 2017