

**ADDENDUM #3**

TO: All Prospective Bidders  
FROM: Steven K. Bennett, P.E, LEED AP BD+C  
DATE: November 3, 2016  
RE: Town of Westernport – New Water Tank & Pump Station  
BBA Contract No. 2014090

**BIDDER QUESTIONS**

1. Do we need to submit MBE/WBE good faith efforts documentation in with the bid?

No, however, if chosen as the low bidder, you will be required to provide documentation that you performed this effort.

2. Is all work associated with the generator (ATS, conduit, cabling, battery charger, batteries, blanket heater, etc.) contained in Alternate #2?

All electrical items and appurtances associated with the installation of the generator installation are included in alternate #2.

3. Can you check to see if power is provided to PRV manhole 1?

Contractor is to furnish and install a 1Ø-120 volt circuit to PRV-1 for operation of PRV(s) in vault (manhole) No. 1, connect to circuit No. A-5 in Panel "A", Wire size: 2 #10 & 1 #10 ground in ¾" conduit. Verify connect point in field.

**ADDITIONAL ITEMS OF INSTRUCTION FOR BID PURPOSES:**

1. Replace Section 00 80 00 with attached section 00 80 00.
2. Replace Section 00 90 00 with attached section 00 90 00.
3. Replace Section C-410 with attached section C-410
4. Replace Sheet C-213 with attached Sheet C-213
5. Replace Sheet C-214 with attached Sheet C-214
6. Replace Sheet C-218 with attached Sheet C-218
7. Replace Sheet C-222 with attached Sheet C-222
8. Replace Sheet C-223 with attached Sheet C-223
9. Replace Sheet C-224 with attached Sheet C-224
10. Replace Sheet C-225 with attached Sheet C-225
11. Replace Sheet C-541 with attached Sheet C-541

Please note that Addendum 3 will only be sent to the firms on the Bidder's List. If you have any questions or comments concerning the accuracy of the questions and answers, please contact me at (301)687-0494 ext. 103 or email me at [bennett\\_brewer@yahoo.com](mailto:bennett_brewer@yahoo.com)

cc: File

Attachments are as follows:

- 00 80 00 Wage Rates
- 00 90 00 DBE
- C-410 Bid Form
- PRV Layout
- Electrical Spec Changes
- Sheet C-213
- Sheet C-214
- Sheet C-218
- Sheet C-222
- Sheet C-223
- Sheet C-224
- Sheet C-225
- Sheet C-541

MEMORANDUM

TO: All Prospective Bidders

FROM: Steven K. Bennet, PE, LEED AP BD+C  
Project Engineer

DATE: November 3, 2016

RE: Town of Westernport – New Water Tank & Pump Station  
BBA Contract No. 2014090  
**ADDENDUM NO. 3**

Bidders shall acknowledge receipt of the Addendum on the Bid Form of the Contract Proposal. Absence of this acknowledgement will be cause for rejection of the contractor's proposal.

The entire proposal book must be submitted with the completed Bid Form to Bennett, Brewer & Associates, LLC.

Bids are due Wednesday, November 9, 2016, 2:00 P.M., local time, **at the office of the Engineer, Bennett Brewer & Associates, LLC, 23 East Main Street, Suite 200, Frostburg, Maryland.**

Upon Receipt, Prospective Bidder **MUST** sign and fax back to Bennett, Brewer & Associates, LLC at (301) 687-0495 or e-mail to [kristie@bbasurvey.com](mailto:kristie@bbasurvey.com).

\_\_\_\_\_  
Name of Corporation

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date